

Certificate of Conformity

Certificate Number: CN-PV-210084

On the basis of the tests undertaken, the samples of the below product have been found to comply with the requirements of the referenced standards at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture. The manufacturer shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant:	Afore New Energy Technology (Shanghai)Co., Ltd. Build No.7, 333 Wanfang Road, Minhang District, Shanghai. China. 201112
Product:	Grid-connected PV inverter
Ratings & Principle Characteristics:	See appendix of Certificate of Conformity
Model:	HNS1000TL-1, HNS1500TL-1, HNS2000TL-1, HNS2500TL-1, HNS3000TL-1
Brand Name<s>:	Afore
Tested according to:	EN 50549-1:2019 Requirements for the connection of generation equipment in parallel with public distribution networks
Certificate Issuing Office Name & Address:	Intertek Testing Services Ltd. Shanghai West Area, 2nd Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China
Test Report No.<s>:	210401416SHA-001

Additional information in Appendix.



Signature

Certification Manager: Qiao Qiao

Date: 25 April 2021

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-210084

Ratings & Principle Characteristics:

Specifications table			
Model	HNS1000TL-1	HNS1500TL-1	HNS2000TL-1
Input:			
Vmax PV (Vdc)	500	500	500
Isc PV (absolute Max.) (A)	18	18	18
Number MPP trackers	1	1	1
Number input strings	1	1	1
Max. PV input current(A)	14	14	14
MPPT voltage range (Vdc)	50-500	50-500	50-500
Vdc range @ full power (Vdc)	70-500	110-500	145-500
Output			
Normal Voltage(V)	L/N/PE 220Vac, 230Vac, 240Vac		
Frequency(Hz)	50 Hz/60 Hz		
Current (normal) (A)	4.4	6.6	8.7
Current (Max. continuous) (A)	6	9	12
Power rating (W)	1000	1500	2000
Power Rating(VA)	1000	1500	2000
Power factor /rated	1(-0.8~+0.8 adjustable)	1(-0.8~+0.8 adjustable)	1(-0.8~+0.8 adjustable)
others			
Protective class	Class I		
Ingress protection (IP)	IP 65		
Temperature(°C)	-25°C to +60°C (up 45°C derating)		
Inverter Isolation	Non-isolated		
Weight (kg)	6 kg		
Dimensions (WxHxD) (mm)	260*280*116		
Software version:	DSP: V06 CPLD: V06 HMI: V06		

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-210084

Specifications table			
Model	HNS2500TL-1	HNS3000TL-1	
Input:			
Vmax PV (Vdc)	500	500	
Isc PV (absolute Max.) (A)	18	18	
Number MPP trackers	1	1	
Number input strings	1	1	
Max. PV input current(A)	14	14	
MPPT voltage range (Vdc)	50-500	50-500	
Vdc range @ full power (Vdc)	180-500	220-500	
Output			
Normal Voltage(V)	L/N/PE 220Vac, 230Vac, 240Vac		
Frequency(Hz)	50 Hz/60 Hz		
Current (normal) (A)	10.9	13.1	
Current (Max. continuous) (A)	13	15	
Power rating (W)	2500	3000	
Power Rating(VA)	2500	3000	
Power factor /rated	1(-0.8~+0.8 adjustable)	1(-0.8~+0.8 adjustable)	
others			
Protective class	Class I		
Ingress protection (IP)	IP 65		
Temperature(°C)	-25°C to +60°C(up 45°C derating)		
Inverter Isolation	Non-isolated		
Weight (kg)	6 kg		
Dimensions (WxHxD) (mm)	260*280*116		
Software version:	DSP: V06 CPLD: V06 HMI: V06		

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.