

Attestation of Conformity

Attestation No: **SHA-AoC-230008**

Applicant Name & Address: Afore New Energy Technology (Shanghai) Co., Ltd.
Building 7, No.333 Wanfang Rd, Minhang District, Shanghai, China. 201112

Factory Name & Address: Afore New Energy Technology (Shanghai) Co., Ltd.
Building 7, No.333 Wanfang Rd, Minhang District, Shanghai, China. 201112

Product Description: Hybrid inverter

Brand Name: Afore

Model: AF*-TH (*=3K, 4K, 5K, 6K, 8K, 10K, 12K, 15K, 17K, 20K, 25K, 30K)
AF*-THP (*=3K, 4K, 5K, 6K, 8K, 10K, 12K)
AF*-THA (*=3K, 4K, 5K, 6K, 8K, 10K, 12K, 15K, 17K)
AF*-THC (*=3K, 4K, 5K, 6K)

Characteristics: See appendix for details

Standards: EN IEC 61000-6-1: 2019; EN IEC 61000-6-3: 2021;

EU Directive: EMC Directive 2014/30/EU

Test Report No: 230601230SHA-001

Issued by: Intertek Testing Services Ltd. Shanghai

Issue date: 2023-07-07

This is to attest that the Technical Construction File for the product listed above has been evaluated against the Essential Safety Requirements of Annex I of the EMC Directive (2014/30/EU). This Attestation can be used in support of the Manufacturers Declaration of Conformity on affixing the CE mark. Product conformity to CE marking is not assured until all other applicable UK Regulations are met in full.

Signature



Name: Gary Hu



APPENDIX: Attestation of Conformity

Ratings & Principle Characteristics:

Specifications table				
Model	AF3K-TH	AF4K-TH	AF5K-TH	AF6K-TH
PV input				
P pv Max(kW)	5	6	7.5	9
Vmax PV (Vdc) (absolute Max.)	1000	1000	1000	1000
Isc PV (absolute Max.) (A)	30*2	30*2	30*2	30*2
Number MPP trackers	2	2	2	2
Number input strings	1/1	1/1	1/1	1/1
Max. PV input current (A)	20*2	20*2	20*2	20*2
MPPT voltage range (Vdc)	150-850	150-850	150-850	150-850
Vdc range @ full power (Vdc)	200-850	200-850	200-850	250-850
Battery (charge/discharge)				
Battery type	Li-ion/Lead-acid			
Battery Normal Voltage (Range) (Vdc)	150-800(Field adapt battery voltage range)			
Max charge/discharge Current(A)	30	30	30	30
Max charge/discharge Power(kW)	3	4	5	6
AC Grid (input and output)				
Normal AC Voltage (VAC)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Normal AC Current (A)	4.4	5.8	7.3	8.7
Max. cont. input/output current (A)	8 / 5.3	10.5 / 7	13 / 8.5	16 / 10.5
Rated Power (kW)	3	4	5	6
Rated Apparent Power (kVA)	3	4	5	6
Max. cont. input/output Power (kW)	4.5 / 3.3	6 / 4.4	7.5 / 5.5	9 / 6.6
Max. cont. Apparent input/output Power (KVA)	4.5 / 3.3	6 / 4.4	7.5 / 5.5	9 / 6.6
Power factor(adjustable)	1.0(-0.8~ +0.8)			
AC Load output (stand alone)				
Normal Voltage (VAC)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Nominal Current (A)	4.4	5.8	7.3	8.7
Max. cont. current (A)	5.3	7	8.5	10.5
Max. cont. Power (kW)	3	4	5	6
Rated Apparent Power (kVA)	3	4	5	6
Max. cont. Apparent Power (kVA)	3	4	5	6
Power factor	1.0			
Others				
Ingress protection (IP)	IP65			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated (PV-AC-BAT)			
Overvoltage category	OVC III (AC Main), OVC II (PV)			
Firmware Version	V1.01			
Software Version	V01			

This Attestation is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Attestation. Only the Client is authorized to permit copying or distribution of this Attestation.. The observations and test/inspection results referenced in this Attestation are relevant only to the sample tested/inspected. This Attestation by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This Attestation is not accredited under a ISO IEC 17065 accreditation.

APPENDIX: Attestation of Conformity

Ratings & Principle Characteristics:

Specifications table				
Model	AF8K-TH	AF10K-TH	AF12K-TH	AF15K-TH
PV input				
P pv Max(kW)	12	15	18	22.5
Vmax PV (Vdc) (absolute Max.)	1000	1000	1000	1000
Isc PV (absolute Max.) (A)	30*2	30*2	30*2	30+48
Number MPP trackers	2	2	2	2
Number input strings	1/1	1/1	1/1	1/2
Max. PV input current (A)	20*2	20*2	20*2	20+32
MPPT voltage range (Vdc)	150-850	150-850	150-850	150-850
Vdc range @ full power (Vdc)	300-850	500-850	500-850	500-850
Battery (charge/discharge)				
Battery type	Li-ion/Lead-acid			
Battery Normal Voltage (Range) (Vdc)	150-800(Field adapt battery voltage range)			
Max charge/discharge Current(A)	30	30	30	50
Max charge/discharge Power(kW)	8	10	12	15
AC Grid (input and output)				
Normal AC Voltage (VAC)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Normal AC Current (A)	11.6	14.5	17.4	21.8
Max. cont. input/output current (A)	20 / 13.5	26 / 17	32 / 21.5	40.5 / 27
Rated Power (kW)	8	10	12	15
Rated Apparent Power (kVA)	8	10	12	15
Max. cont. input/output Power (kW)	12 / 8.8	15 / 11	18 / 13.2	22.5 / 16.5
Max. cont. Apparent input/output Power (kVA)	12 / 8.8	15 / 11	18 / 13.2	22.5 / 16.5
Power factor(adjustable)	1.0(-0.8~ +0.8)			
AC Load output (stand alone)				
Normal Voltage (VAC)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Nominal Current (A)	11.6	14.5	17.4	21.8
Max. cont. current (A)	13.5	17	21.5	27
Max. cont. Power (kW)	8	10	12	15
Rated Apparent Power (kVA)	8	10	12	15
Max. cont. Apparent Power (kVA)	8	10	12	15
Power factor	1.0			
Others				
Ingress protection (IP)	IP65			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated (PV-AC-BAT)			
Overvoltage category	OVC III (AC Main), OVC II (PV)			
Firmware Version	V1.01			
Software Version	V01			

This Attestation is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Attestation. Only the Client is authorized to permit copying or distribution of this Attestation.. The observations and test/inspection results referenced in this Attestation are relevant only to the sample tested/inspected. This Attestation by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This Attestation is not accredited under a ISO IEC 17065 accreditation.

APPENDIX: Attestation of Conformity

Ratings & Principle Characteristics:

Specifications table				
Model	AF3K-THP	AF4K-THP	AF5K-THP	AF6K-THP
PV input				
P pv Max(kW)	5	6	7.5	9
Vmax PV (Vdc) (absolute Max.)	1000	1000	1000	1000
Isc PV (absolute Max.) (A)	30*2	30*2	30*2	30*2
Number MPP trackers	2	2	2	2
Number input strings	1/1	1/1	1/1	1/1
Max. PV input current (A)	20*2	20*2	20*2	20*2
MPPT voltage range (Vdc)	150-850	150-850	150-850	150-850
Vdc range @ full power (Vdc)	200-850	200-850	200-850	250-850
Battery (charge/discharge)				
Battery type	Li-ion/Lead-acid			
Battery Normal Voltage (Range) (Vdc)	80-600(Field adapt battery voltage range)			
Max charge/discharge Current(A)	50	50	50	50
Max charge/discharge Power(kW)	3	4	5	6
AC Grid (input and output)				
Normal AC Voltage (VAC)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Normal AC Current (A)	4.4	5.8	7.3	8.7
Max. cont. input/output current (A)	8 / 5.3	10.5 / 7	13 / 8.5	16 / 10.5
Rated Power (kW)	3	4	5	6
Rated Apparent Power (kVA)	3	4	5	6
Max. cont. input/output Power (kW)	4.5 / 3.3	6 / 4.4	7.5 / 5.5	9 / 6.6
Max. cont. Apparent input/output Power (KVA)	4.5 / 3.3	6 / 4.4	7.5 / 5.5	9 / 6.6
Power factor(adjustable)	1.0(-0.8~ +0.8)			
AC Load output (stand alone)				
Normal Voltage (VAC)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Nominal Current (A)	4.4	5.8	7.3	8.7
Max. cont. current (A)	5.3	7	8.5	10.5
Max. cont. Power (kW)	3	4	5	6
Rated Apparent Power (kVA)	3	4	5	6
Max. cont. Apparent Power (kVA)	3	4	5	6
Power factor	1.0			
Others				
Ingress protection (IP)	IP65			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated (PV-AC-BAT)			
Overvoltage category	OVC III (AC Main), OVC II (PV)			
Firmware Version	V1.01			
Software Version	V01			

This Attestation is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Attestation. Only the Client is authorized to permit copying or distribution of this Attestation.. The observations and test/inspection results referenced in this Attestation are relevant only to the sample tested/inspected. This Attestation by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This Attestation is not accredited under a ISO IEC 17065 accreditation.

APPENDIX: Attestation of Conformity

Ratings & Principle Characteristics:

Specifications table			
Model	AF8K-THP	AF10K-THP	AF12K-THP
PV input			
P pv Max(kW)	12	15	18
Vmax PV (Vdc) (absolute Max.)	1000	1000	1000
Isc PV (absolute Max.) (A)	30*2	30*2	30*2
Number MPP trackers	2	2	2
Number input strings	1/1	1/1	1/1
Max. PV input current (A)	20*2	20*2	20*2
MPPT voltage range (Vdc)	150-850	150-850	150-850
Vdc range @ full power (Vdc)	300-850	500-850	500-850
Battery (charge/discharge)			
Battery type	Li-ion/Lead-acid		
Battery Normal Voltage (Range) (Vdc)	80-600(Field adapt battery voltage range)	120-650(Field adapt battery voltage range)	
Max charge/discharge Current(A)	50	50	50
Max charge/discharge Power(kW)	8	10	12
AC Grid (input and output)			
Normal AC Voltage (VAC)	3P+N+PE/3P+PE 230/400		
Frequency (Hz)	50		
Normal AC Current (A)	11.6	14.5	17.4
Max. cont. input/output current (A)	20 / 13.5	26 / 17	32 / 21.5
Rated Power (kW)	8	10	12
Rated Apparent Power (kVA)	8	10	12
Max. cont. input/output Power (kW)	12 / 8.8	15 / 11	18 / 13.2
Max. cont. Apparent input/output Power (kVA)	12 / 8.8	15 / 11	18 / 13.2
Power factor(adjustable)	1.0(-0.8~ +0.8)		
AC Load output (stand alone)			
Normal Voltage (VAC)	3P+N+PE/3P+PE 230/400		
Frequency (Hz)	50		
Nominal Current (A)	11.6	14.5	17.4
Max. cont. current (A)	13.5	17	21.5
Max. cont. Power (kW)	8	10	12
Rated Apparent Power (kVA)	8	10	12
Max. cont. Apparent Power (kVA)	8	10	12
Power factor	1.0		
Others			
Ingress protection (IP)	IP65		
Protective class	Class I		
Temperature (°C)	-25°C to +60°C (Derating 45°C)		
Inverter Isolation	Non-isolated (PV-AC-BAT)		
Overvoltage category	OVC III (AC Main), OVC II (PV)		
Firmware Version	V1.01		
Software Version	V01		

This Attestation is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Attestation. Only the Client is authorized to permit copying or distribution of this Attestation.. The observations and test/inspection results referenced in this Attestation are relevant only to the sample tested/inspected. This Attestation by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This Attestation is not accredited under a ISO IEC 17065 accreditation.

APPENDIX: Attestation of Conformity

Ratings & Principle Characteristics:

Specifications table				
Model	AF17K-TH	AF20K-TH	AF25K-TH	AF30K-TH
PV input				
P pv Max(kW)	25.5	30	37.5	45
Vmax PV (Vdc) (absolute Max.)	1000	1000	1000	1000
Isc PV (absolute Max.) (A)	48*2	48*2	60*2	60*2
Number MPP trackers	2	2	2	2
Number input strings	2/2	2/2	2/2	2/2
Max. PV input current (A)	32*2	32*2	40*2	40*2
MPPT voltage range (Vdc)	150-850	150-850	150-850	150-850
Vdc range @ full power (Vdc)	500-850	500-850	500-850	500-850
Battery (charge/discharge)				
Battery type	Li-ion/Lead-acid			
Battery Normal Voltage (Range) (Vdc)	150-800(Field adapt battery voltage range)			
Max charge/discharge Current(A)	50	50	60	60
Max charge/discharge Power(kW)	17	20	25	30
AC Grid (input and output)				
Normal AC Voltage (VAC)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Normal AC Current (A)	24.7	29	36.3	43.5
Max. cont. input/output current (A)	45 / 30	48 / 32	60 / 40	72 / 48
Rated Power (kW)	17	20	25	30
Rated Apparent Power (kVA)	17	20	25	30
Max. cont. input/output Power (kW)	25.5 / 18.7	30 / 22	37.5 / 27.5	45 / 33
Max. cont. Apparent input/output Power (kVA)	25.5 / 18.7	30 / 22	37.5 / 27.5	45 / 33
Power factor(adjustable)	1.0(-0.8~ +0.8)			
AC Load output (stand alone)				
Normal Voltage (VAC)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Nominal Current(A)	24.7	29	36.3	43.5
Max. cont. current (A)	30	32	40	48
Max. cont. Power (kW)	17	20	25	30
Rated Apparent Power (kVA)	17	20	25	30
Max. cont. Apparent Power (kVA)	17	20	25	30
Power factor	1.0			
Others				
Ingress protection (IP)	IP65			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated (PV-AC-BAT)			
Overvoltage category	OVC III (AC Main), OVC II (PV)			
Firmware	V1.01			
Software Version	V01			

This Attestation is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Attestation. Only the Client is authorized to permit copying or distribution of this Attestation.. The observations and test/inspection results referenced in this Attestation are relevant only to the sample tested/inspected. This Attestation by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This Attestation is not accredited under a ISO IEC 17065 accreditation.

APPENDIX: Attestation of Conformity

Ratings & Principle Characteristics:

Specifications table				
Model	AF3K-THA	AF4K-THA	AF5K-THA	AF6K-THA
PV input				
P pv Max(kW)	5	6	7.5	9
Vmax PV (Vdc) (absolute Max.)	1000	1000	1000	1000
Isc PV (absolute Max.) (A)	30*2	30*2	30*2	30*2
Number MPP trackers	2	2	2	2
Number input strings	1/1	1/1	1/1	1/1
Max. PV input current (A)	20*2	20*2	20*2	20*2
MPPT voltage range (Vdc)	150-850	150-850	150-850	150-850
Vdc range @ full power (Vdc)	200-850	200-850	200-850	200-850
Battery (charge/discharge)				
Battery type	Li-ion/Lead-acid			
Battery Normal Voltage Range (Vdc)	150-600(Field adapt battery voltage range)			
Max charge/discharge Current(A)	30	30	30	30
Max charge/discharge Power(kW)	3	4	5	6
AC Grid (input and output)				
Normal AC Voltage (VAC)	3P+PE/3P 133/230			
Frequency (Hz)	50			
Normal AC Current (A)	7.6	10.1	12.6	15.1
Max. cont. input/output current (A)	16 / 10.5	20 / 13.5	26 / 17	32 / 21.5
Rated Power (kW)	3	4	5	6
Rated Apparent Power (kVA)	3	4	5	6
Max. cont. input/output Power (kW)	4.5 / 3.3	6 / 4.4	7.5 / 5.5	9 / 6.6
Max. cont. Apparent input/output Power (kVA)	4.5 / 3.3	6 / 4.4	7.5 / 5.5	9 / 6.6
Power factor(adjustable)	1.0(-0.8~ +0.8)			
AC Load output (stand alone)				
Normal Voltage (VAC)	3P+PE/3P 133/230			
Frequency (Hz)	50			
Nominal Current (A)	7.6	10.1	12.6	15.1
Max. cont. current (A)	10.5	13.5	17	21.5
Max. cont. Power (kW)	3	4	5	6
Rated Apparent Power (kVA)	3	4	5	6
Max. cont. Apparent Power (kVA)	3	4	5	6
Others				
Ingress protection (IP)	IP65			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated (PV - AC - BAT)			
Overvoltage category	OVC III (AC Main), OVC II (PV)			
Firmware	V1.01			
Software Version	V01			

This Attestation is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Attestation. Only the Client is authorized to permit copying or distribution of this Attestation.. The observations and test/inspection results referenced in this Attestation are relevant only to the sample tested/inspected. This Attestation by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This Attestation is not accredited under a ISO IEC 17065 accreditation.

APPENDIX: Attestation of Conformity

Ratings & Principle Characteristics:

Specifications table				
Model	AF3K-THC	AF4K-THC	AF5K-THC	AF6K-THC
PV input				
P _{pv} Max(kW)	5	6	7.5	9
V _{max} PV (Vdc) (absolute Max.)	1000	1000	1000	1000
I _{sc} PV (absolute Max.) (A)	30*2	30*2	30*2	30*2
Number MPP trackers	2	2	2	2
Number input strings	1/1	1/1	1/1	1/1
Max. PV input current (A)	20*2	20*2	20*2	20*2
MPPT voltage range (Vdc)	150-850	150-850	150-850	150-850
Vdc range @ full power (Vdc)	200-850	200-850	200-850	200-850
Battery (charge/discharge)				
Battery type	Li-ion/Lead-acid			
Battery Normal Voltage Range (Vdc)	80-600(Field adapt battery voltage range)			
Max charge/discharge Current(A)	50	50	50	50
Max charge/discharge Power(kW)	3	4	5	6
AC Grid (input and output)				
Normal AC Voltage (VAC)	3P+PE/3P 133/230			
Frequency (Hz)	50			
Normal AC Current (A)	7.6	10.1	12.6	15.1
Max. cont. input/output current (A)	16 / 10.5	20 / 13.5	26 / 17	32 / 21.5
Rated Power (kW)	3	4	5	6
Rated Apparent Power (kVA)	3	4	5	6
Max. cont. input/output Power (kW)	4.5 / 3.3	6 / 4.4	7.5 / 5.5	9 / 6.6
Max. cont. Apparent input/output Power (kVA)	4.5 / 3.3	6 / 4.4	7.5 / 5.5	9 / 6.6
Power factor(adjustable)	1.0(-0.8~ +0.8)			
AC Load output (stand alone)				
Normal Voltage (VAC)	3P+PE/3P 133/230			
Frequency (Hz)	50			
Nominal Current (A)	7.6	10.1	12.6	15.1
Max. cont. current (A)	10.5	13.5	17	21.5
Max. cont. Power (kW)	3	4	5	6
Rated Apparent Power (kVA)	3	4	5	6
Max. cont. Apparent Power (kVA)	3	4	5	6
Others				
Ingress protection (IP)	IP65			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated (PV - AC - BAT)			
Overvoltage category	OVC III (AC Main), OVC II (PV)			
Firmware	V1.01			
Software Version	V01			

This Attestation is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Attestation. Only the Client is authorized to permit copying or distribution of this Attestation.. The observations and test/inspection results referenced in this Attestation are relevant only to the sample tested/inspected. This Attestation by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This Attestation is not accredited under a ISO IEC 17065 accreditation.

APPENDIX: Attestation of Conformity

Ratings & Principle Characteristics:

Specifications table					
Model	AF8K-THA	AF10K-THA	AF12K-THA	AF15K-THA	AF17K-THA
PV input					
P _{pv} Max(kW)	12	15	18	22.5	25.5
V _{max} PV (Vdc) (absolute Max.)	1000	1000	1000	1000	1000
I _{sc} PV (absolute Max.) (A)	30+48	48*2	48*2	60*2	60*2
Number MPP trackers	2	2	2	2	2
Number input strings	1/2	2/2	2/2	2/2	2/2
Max. PV input current (A)	20+32	32*2	32*2	40*2	40*2
MPPT voltage range (Vdc)	150-850	150-850	150-850	150-850	150-850
Vdc range @ full power (Vdc)	200-850	200-850	250-850	300-850	300-850
Battery (charge/discharge)					
Battery type	Li-ion/Lead-acid				
Battery Normal Voltage Range (Vdc)	150-600(Field adapt battery voltage range)				
Max charge/discharge Current(A)	50	50	50	60	60
Max charge/discharge Power(kW)	8	10	12	15	17
AC Grid (input and output)					
Normal AC Voltage (VAC)	3P+PE/3P 133/230				
Frequency (Hz)	50				
Normal AC Current (A)	20.1	25.1	30.1	37.6	42.7
Max. cont. input/output current (A)	40.5 / 27	45 / 30	48 / 32	60 / 40	72 / 48
Rated Power (kW)	8	10	12	15	17
Rated Apparent Power (kVA)	8	10	12	15	17
Max. cont. input/output Power (kW)	12 / 8.8	15 / 11	18 / 13.2	22.5 / 16.5	25.5 / 18.7
Max. cont. Apparent input/output Power (kVA)	12 / 8.8	15 / 11	18 / 13.2	22.5 / 16.5	25.5 / 18.7
Power factor(adjustable)	1.0 (-0.8~ +0.8)				
AC Load output (stand alone)					
Normal Voltage (VAC)	3P+PE/3P 133/230				
Frequency (Hz)	50				
Nominal Current (A)	20.1	25.1	30.1	37.6	42.7
Max. cont. current (A)	27	30	32	40	48
Max. cont. Power (kW)	8	10	12	15	17
Rated Apparent Power (kVA)	8	10	12	15	17
Max. cont. Apparent Power (kVA)	8	10	12	15	17
Others					
Ingress protection (IP)	IP65				
Protective class	Class I				
Temperature (°C)	-25°C to +60°C (Derating 45°C)				
Inverter Isolation	Non-isolated (PV - AC - BAT)				
Overvoltage category	OVC III (AC Main), OVC II (PV)				
Firmware	V1.01				
Software Version	V01				

This Attestation is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Attestation. Only the Client is authorized to permit copying or distribution of this Attestation.. The observations and test/inspection results referenced in this Attestation are relevant only to the sample tested/inspected. This Attestation by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This Attestation is not accredited under a ISO IEC 17065 accreditation.