

# Certificate of Conformity

Certificate Number: CN-PV-230305

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

<b>Applicant:</b>	Afore New Energy Technology (Shanghai) Co., Ltd. Build No.7, 333 Wanfang Road, Minhang District, Shanghai. China. 201112
<b>Product:</b>	Grid-connected PV inverter
<b>Ratings &amp; Principle Characteristics:</b>	See appendix of Certificate of Conformity
<b>Model:</b>	BNT030KTL, BNT036KTL, BNT040KTL, BNT050KTL, BNT060KTL
<b>Brand Name&lt;s&gt;:</b>	Afore
<b>Product Complies with:</b>	G99 Issue 1 Amendment 9, 3 October 2022
<b>Certificate Issuing Office Name &amp; Address:</b>	Intertek Testing Services Ltd. Shanghai West Area, 2 <sup>nd</sup> Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
<b>Test Report No.&lt;s&gt;:</b>	230501662SHA-001

Additional information in Appendix.



Signature

Certification Manager: Qiao Qiao

Date: 07 June 2023



PRD N° 306B

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230305

### Ratings & Principle Characteristics:

Specifications table					
Model	BNT030KTL	BNT036KTL	BNT040KTL	BNT050KTL	BNT060KTL
<b>PV input</b>					
P <sub>pv</sub> Max(W)	45000	54000	60000	75000	90000
V <sub>max</sub> PV (Vdc) (absolute Max.)	1100	1100	1100	1100	1100
I <sub>sc</sub> PV (absolute Max.) (A)	48 x 2	48 x 3	48 x 3	48 x 3	48 x 4
Number MPP trackers	2	3	3	3	4
Number input strings	2/3	2/2/2	2/2/2	2/2/3	2/2/2/2
Max. PV input current / strings (A)	38 x 2	38 x 3	38 x 3	40 x 3	38 x 4
MPPT voltage range (Vdc)	200-1000	200-1000	200-1000	200-1000	200-1000
Vdc range @ full power (Vdc)	500-850	500-850	500-850	500-850	500-850
<b>AC Grid (output)</b>					
Normal AC Voltage (V <sub>AC</sub> )	3P+N+PE/3P+PE 230/400				
Frequency (Hz)	50				
Normal AC Current (A)	43.5	52.2	58	72.5	87
Max. cont. output current (A)	48	60	65	80	96
Normal Power (W)	30000	36000	40000	50000	60000
Rated Apparent Power (VA)	30000	36000	40000	50000	60000
Max. cont. Power (W)	30000	36000	40000	50000	60000
Max. cont. Apparent Power (VA)	30000	36000	40000	50000	60000
Power factor(adjustable)	1.0(-0.8~ +0.8)				
<b>Others</b>					
Protective class	Class I				
Ingress protection (IP)	IP65				
Temperature (°C)	-25°C to +60°C (Derating 45°C)				
Inverter Isolation	Non-isolated				
Overvoltage category	OVC III (AC Main), OVC II (PV)				
Software version	V06				

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.